





Wednesday 11 Sep 2013

# City Council of Frankfurt/Main




STADT  FRANKFURT AM MAIN

## Energy performance certificate


In accordance with Sections 16 ff. EnEV

Valid until: 2024/11/24


<b>Building</b>	<b>Construction Bureau</b>	
Address	<b>Gerbermühlstrasse 48</b>	
Main usage	Administrative building with normal technical equipme	9 711 m <sup>2</sup>
Sonderzone	Care centers	350 m <sup>2</sup>
Net floor space		<b>10 062 m<sup>2</sup></b>



### Heating energy specific consumption 2006 - 2009 (including hot water) Costs/year



### Power specific consumption 2006 - 2009 Costs/year



◀ ▶ ... **Certificate** | Umrechnung BGF-NGF | Klassengrenzen Heizung | Klassengrenzen Strom | Klasseng ...




# Germany:

## Reduction of energy demand of residential buildings

### Entwicklung des energiesparenden Bauens

Primärenergiebedarf Heizung (kWh/m<sup>2</sup>a)



- 1977: Thermal Insulation Ordinance (WSchV 1977)
- 1984: Thermal Insulation Ordinance (WSchV 1984)
- 1995: Thermal Insulation Ordinance (WSchV 1995)

- 2002: EnEV 2002
- 2004: EnEV 2004
- 2007: EnEV 2007
- 2009: EnEV 2009



Wednesday 11 Sep 2013

# City Council of Frankfurt/Main

## Category limits for electricity

Year of completion: **2004**  
Size: **net floor area**

Flow-off rates for roofs

Data source: IEMB database as of: 09.11.2006

**2007** **2009 based**

BZK	Building category	Number Values	Lower limits for categories (kWh/m <sup>2</sup> a)							Comparative values in EnE (kWh/m <sup>2</sup> a)			
			A	B	C	D	E	F	G	<=3,500 m <sup>2</sup>	>3,500 m <sup>2</sup>	<=3,500 m <sup>2</sup>	>3,500 m <sup>2</sup>
1100	Parliamentary building	34	0.0	19.0	25.2	30.0	33.5	49.2	67.1	43	43	40	40
1200	Court buildings	637	0.0	13.5	16.4	20.9	24.0	28.9	36.4	25	35	20	25
1300	Administration buildings	4 562	0.0	14.7	20.3	25.8	32.4	40.9	55.2	37	45	20	30
1310	Administrative building with normal tech	2 270	0.0	14.1	19.1	23.9	28.7	35.0	46.5	33	40	20	30
1313	City halls	51	0.0	20.8	26.9	34.1	38.1	42.4	53.9	36	40	35	35
1320	Administrative buildings with a lot of eq	164	0.0	12.9	20.6	32.0	44.6	57.2	98.6	53	65	40	40
1340	Police building	1 812	0.0	15.8	22.7	30.4	38.1	47.6	63.0	41	40	30	30
1350	Data centers	12	0.0	124.0	125.9	143.6	211.9	311.9	558.0	231	220	155	155
2000	Educational/research building	866	0.0	15.8	24.7	35.5	48.8	69.5	116.4	75	75	65	65
2100	Lecture halls	37	0.0	19.5	29.1	42.7	46.5	52.9	103.1	60	60	40	40
2200	Research and educational institutes	463	0.0	14.3	22.8	32.0	46.4	63.3	113.3	74	75	65	65
2300	Research institutes	149	0.0	16.8	35.8	56.8	81.2	108.8	147.8	83	90	65	65
3200	Hospitals for acute diseases	17	0.0	46.9	89.0	121.1	150.9	153.8	216.4	128	128	125	80
3300	Special clinics (addictions, etc.)	30	0.0	39.3	43.8	51.0	55.7	61.1	71.8	55	55	135	135
3400	Care centers (elderly, handicapped)	17	0.0	17.8	28.8	35.9	43.9	49.5	63.0	40	40	40	40
4000	Schools	3 126	0.0	8.5	11.0	13.6	17.4	22.6	30.6	19	20	15	15
4100	General schools	1 571	0.0	7.6	9.5	11.4	13.3	16.1	21.2	15	15	10	10
4110	Elementary schools	684	0.0	7.3	9.2	11.1	13.0	15.3	20.0	14	15	10	10




If I'd know the  
energy  
consumption  
of this building...?







# Let's speak kWh / (m<sup>2</sup>·a)






6000 kWh in Dec 2013...  
Is that **HIGH** or **LOW** energy consumption?



## SANEDI Building Energy Consumption Feed

TENANT COMPARISON    **SANEDI HVAC AND INDOOR POWER**







6000 kWh for Dec 2013...  
94,000 kWh for Jan-Nov 2013  
**Ca. 100,000 kWh total 2013**

**Rental space: ca. 1,000 m<sup>2</sup>**



kWh / (m<sup>2</sup>·a)  
100,000 / (1,000 x 1) =  
**100 kWh/ (m<sup>2</sup>·a)**

**Is that HIGH or LOW energy consumption?**





## Office building: 100 kWh/ (m<sup>2</sup>-a) (electricity) **high** or **low** ?





## Some more work to do in SA!



**Table 3 — Maximum annual consumption per building classification for each climatic zone**

1	2	3 4 5 6 7 8					
		Maximum energy consumption kWh/m <sup>2</sup>					
		Climatic zone <sup>a</sup>					
Classification of occupancy of building	Description of building	1	2	3	4	5	6
A1	Entertainment and public assembly	420	400	440	390	400	420
A2	Theatrical and indoor sport	420	400	440	390	400	420
A3	Places of instruction	420	400	440	390	400	420
A4	Worship	120	115	125	110	115	120
F1	Large shop	240	245	260	240	260	255
C1	Office	200	100	210	185	100	200
H1	Hotel	650	600	585	600	620	630

NOTE 1 The annual consumption per square metre shall be based on the sum of the monthly consumption of 12 consecutive months.

NOTE 2 Non-electrical consumption, such as fossil fuels, shall be accounted for on a non-renewable primary energy thermal equivalence basis by converting megajoules to kilowatt hours.

<sup>a</sup> The climatic zones shall be as given in annex A.

### South African SANS 10400XA/204 – Prescriptive path to compliance

Source: SABS

Use (examples)	Comparative value according to the ordinance of 2009	
	Heating and hot water	Electricity
	final energy demand [kWh/(m <sup>2</sup> a)]	
Hotels, mid-range	85	55
Restaurants	205	95
Cinema	55	80
Gyms	120	35
Multipurpose halls	240	40
Indoor swimming pools	385	105
Non-food trade, small	135	45
Food trade, small	125	75
Department stores, shopping centres	70	85
Hospitals, large	175	80
Office buildings, only heated	105	35
Office buildings, heated and ventilated	110	85



Consumption!

### German Energy Saving Ordinance 2009


Source: BBSR, Schettler-Koehler, Kunkel



## Progress in SA



## Revision of climatic maps



## 1<sup>st</sup> SA EPC (SANS 1544)



## Proposal for revision of SANS 204/SANS 10400XA max. energy consumption data (plug load & operational energy)


Classification	Maximum regulated energy consumption [kWh/m2.a]	Anticipated plug load [kwh/m2.a]
Entertainment and public assembly	88	45
Theatrical and indoor sport	96	45
Places of instruction	58	28
Worship	52	45
Large shop	146	38
Offices	80	45
Hotel	104	42
<b>NEW:</b> Residential	56	24
Hospitals	134	62





# Continued revision of maximum allowable energy targets

New proposed figures for offices



8% reduction on previous allowance required every two years





Thursday 12 Sep 2013

## KfW Promotional Bank, Frankfurt



### KfW Promotional Programme: Energy Efficient Refurbishment *What incentives are offered?*



Support/Bonus	Subsidised low interest loans	Partial debt relief (bonus)
KfW-115 Effizienzhaus	1.0% p.a. (eff.)	7.5 % up to R52,500
KfW-Denkmal Effizienzhaus	1.0% p.a. (eff.)	10.0 % up to R105,000
KfW-100 Effizienzhaus	1.0% p.a. (eff.)	12.5 % up to R131,250
KfW-85 Effizienzhaus	1.0% p.a. (eff.)	15.0 % up to R157,500
KfW-70 Effizienzhaus	1.0% p.a. (eff.)	17.5 % up to R183,750
KfW-55 Effizienzhaus	1.0% p.a. (eff.)	20.0% up to R210,000





# Thank you!

South African - German Energy Programme (SAGEN)  
Energy Efficiency Component

Christian.Borchard@giz.de