

## NATIONAL ASSEMBLY QUESTION: 1502

### **Mrs C Dudley (ACDP) to ask the Minister of Energy:**

What is her department's state of readiness to deal with the effects of (a) an earthquake, (b) a tsunami and (c) a radiation leakage in light of the recent increase in earthquakes worldwide and the fact that the Koeberg Nuclear Power Station is situated alongside the Milnerton fault line? NW1535E

### **REPLY**

The Disaster Management Act requires the Minister of Energy, as the responsible person for the coordination and management of matters related to nuclear energy, to prepare a disaster management plan for nuclear disasters. The National Nuclear Disaster Management Plan was approved and submitted to the National Disaster Management Centre in 2005. This plan deals with how a nuclear emergency must be handled. There are emergency plans for both the Koeberg Nuclear Power Plant and the Pelindaba Materials Research Reactor. These emergency plans are tested regularly to check the response of the different players, i.e. operator, local and national authorities.

Koeberg, as originally designed and subsequently modified by Eskom, is in line with modern international safety standards and also has defence-in-depth measures that are relevant to its location. Following the accident at Fukushima, Eskom performed the necessary tests to verify the capability of all equipment required to respond to severe and beyond design basis accidents.

The following measures are in place:

- Koeberg is designed to withstand an **earthquake** of level 7 on Richter Scale
- The Koeberg terrace height is 8 metre above mean sea level,
- Koeberg is supplied from four 400 kV lines and one 132 kV line **connected to the national grid**.
- If there is a problem with this supply from the national grid, a dedicated power station is available
- Additional backup generators are on site
- It is equipped to facilitate the addition of cooling water to spent fuel pools and containment buildings should it be required.
- An emergency plan is in place. It has been tested and found to be adequate